



## **HOLCIM BULACAN PLANT**

### **Improvement of Power Factor at Crusher through Reduction of Medium Voltage and Load-based Regulation of Capacitor Operation**

#### **SUMMARY OF THE OPTION**

HOLCIM (Formerly Union Cement Corporation) Bulacan Plant is located in Bulacan, the Philippines, and produces about 1.9 million metric tons of cement per year. An assessment of the plant's electric system found that the frequencies of 16 feeders at the plant's substation were higher than 60 Hz and that the power factor for eight feeders was less than 0.85, resulting in penalty charges in the electricity bill. To reduce the power factor, the voltage of feeders was reduced to be closer to the design voltages. Financial savings result from reduced penalty charges by the electricity supplier and the payback period was immediate. There are no energy savings because the power factor has no influence on electricity consumption.

#### **KEY WORDS**

Cement, Philippines, Electricity, Crusher, Capacitor Bank

#### **OBSERVATIONS**

An assessment was carried out of 16 feeders at the substation and voltage (Volt), power use (kW), frequency (Hz) and power factor (PF) were measured. It was found that:

- The frequency of 16 feeders in the substation is often greater than 60 Hz, resulting in increased electricity consumption.
- The power factor for eight feeders was less than 0.85, which results in penalty charges by the electricity supplier.
- The main feeder 17, located at Transformer 1, has a leading power factor. It is understood that the leading factor occurs when the crushers are not operating.

#### **OPTIONS**

An attempt was made to improve the power factor by slightly reducing the medium voltage (4160 V) of the feeders. The charging voltage was compared with the design voltage on the nameplate of the capacitors, and reduced to be closer to the design voltage. This resulted in slight improvements of the power factor for nine feeders. Improvements for other capacitors could be achieved, in particular for those operating continuously.

It is recommended to regulate the loads of capacitor operations as shown in the following table.

Feeder	Before				After			
	Volt	kW	Hz	PF	Volt	kW	Hz	PF
Feeder 01 Packhouse 2	4137	58	60.06	-0.732	4093	50	60.03	-0.727
Feeder 02 Finish Mill 3 Main Drive	4141	0	60.06	1	4097	0	60.04	1
Feeder 03 Finish Mill 3 Aux	4144	511	60.07	-0.851	4100	499	60.04	-0.843
Feeder 04 Finish Mill 4 Main Drive	4132	4464	60.06	-0.924	4086	4438	60.06	-0.926



Feeder	Before				After			
	Volt	kW	Hz	PF	Volt	kW	Hz	PF
Feeder 05 Finish Mill 4 Aux	4140	1285	60.07	-0.743	4094	1243	60.06	-0.746
Feeder 06 Raw Mill 4 Fan/BE	4141	66	60.07	-0.741	4095	62	60.05	-0.720
Feeder 07 Power Capacitor	4135	0	60.06	1	4087	0	60.06	1
Feeder 08 Kiln Cooler	4123	2315	60.07	-0.789	4066	2296	60.05	-0.790
Feeder 09 PH/Kiln/Baghouse fan	4127	3834	60.06	-0.842	4070	3819	60.07	-0.845
Feeder 10 Raw Mill 3 Fan/BE	4123	2732	60.06	-0.881	4066	2716	60.07	-0.872
Feeder 11 Raw Mill 3 Main Drive/Aux	4130	3306	60.05	-0.870	4073	3531	60.07	-0.874
Feeder 13 Raw Mill 4 Main Drive/Aux	4128	356	60.05	-0.970	4071	451	60.05	-0.947
Feeder 14 Coal Plant 3 and 4	4126	900	60.08	-0.794	4072	913	60.06	-0.808
Transformer 1 Main Feeder 17	116053	230	60.07	0.723	116267	270	60.06	0.852
Transformer 2 Main Feeder 19	116403	6320	60.06	-0.888	116480	6260	60.04	-0.889
Transformer 3 Main Feeder 18	114193	13360	60.07	-0.836	114237	13610	60.04	-0.836

## RESULTS

### Financial benefits

- Investment: none
- Annual cost savings: Reduced penalty charges on the electricity bill because of reduced power factor
- Payback period: immediate

### Environmental benefits

- None, because reducing the power factor does not result in reduced electricity consumption

## FOR MORE INFORMATION

### ***GERIAP National Focal Point for the Philippines***

Dr. Alice B. Herrera

Officer-in-Charge, Fuels and Energy Division

Industrial Technology Development Institute

Gen. Santos Ave., Bicutan, Taguig City, Metro Manila Philippines 1631

Tel: +632 837 2071 ext 2190

Tel fax: +632 837 2071 ext 2204

E-mail: [aherrera@dost.gov.ph](mailto:aherrera@dost.gov.ph), [abherrera@pacific.net.ph](mailto:abherrera@pacific.net.ph)

### ***GERIAP Company in the Philippines***

Mr. Julius B. Yballe, SVP Operations

HOLCIM – Bulacan Plant

Philippines

Tel: +632 7322230

Tel fax: +632 7322564

E-mail: [julius.yballe@holcim.com](mailto:julius.yballe@holcim.com)

### ***Disclaimer:***

*This case study was prepared as part of the project “Greenhouse Gas Emission Reduction from Industry in Asia and the Pacific” (GERIAP). While reasonable efforts have been made to ensure that the contents of this publication are factually correct, UNEP does not accept responsibility for the accuracy or completeness of the contents, and shall not be liable for any loss or damage that may be occasioned directly or indirectly through the use of, or reliance on, the contents of this publication. © UNEP, 2006.*